

# BFP-8F and BFP-9

## Hose Connection Vacuum Breakers

**WILKINS®**

### INSTALLATION INSTRUCTIONS

1. Screw threaded female end of BFP-8F/BFP-9 to any hose thread faucet.
2. To prevent any unauthorized removal or tampering of the device, the BFP-8F/BFP-9 is furnished with a break-away head set screw.

### APPLICATIONS

The WILKINS Model BFP-8F/BFP-9 is to be installed on water lines where a cross-connection would result in pollution of potable water. If a health hazard could result from a cross-cross connection, use a WILKINS Model 375XL.

### CAUTION

Install device only in area where discharge will not cause water damage.

WARNING: This product is NOT Lead Free in accordance with U.S. Federal Law and is illegal in the U.S. for use in potable services or to install in water systems anticipated for human consumption.

**WILKINS**

**Zurn Water, LLC - Wilkins**  
1747 Commerce Way, Paso Robles, CA 93446 Phone:855-663-9876 Fax:805-238-5766

[www.zurn.com](http://www.zurn.com)

ISBFP (REV. A 7/26)